Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EQ361

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KEN SULLIVAN	Phone #: (608)274-0509
Mailing Address: 4125 NAKOMA RD	
City: MADISON	State: WI — Zip Code: 53711
County: Waushara	Co. Permit #: — Notification #: — Completed: 06-10-1992
Well Constructor (Business Name): FARAGO, JOE	Lic. #: 284 — Facility ID # (Public Wells):
Address: 606 W POPLAR ST, PLAINFIELD WI 54966-9673	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 15

1. Well Location

Town of COLOMA — Fire # (if avail.): N152

Street Address or Road Name and Number:

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): 43.98607 °N -89.55786 °W — Method Code: GPS008

NE SE or Govt Lot #: — Section: 33 — Township: 18 N — Range: 8 E

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: NOT ENOUGH WATER

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	120

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	S			SAND	Surface	31
	S	G		SAND GRAVEL	31	66
N	S			FINE SAND	66	78
N	S	C		FINE SAND @ CLAY CHIPS	78	82
N	S			FINE SAND	82	105
M	S			MED SAND	105	120

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A1 USS STEEL A53 19.97# PER FT WELDED 6.625"OD X 280 WALL TESTED 2800 PSI	Surface	116
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	#15 JOHNSON	116	120

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
POWDER BENTONITE ALONG CASING	Surface	0	

9. Static Water Level

41 ft. below ground surface

10. Pump Test

Pumping level 42 ft. below surface

Pumping at 15 GP for 1.5 Hrs.

Pumping Method ?

11. Well Is

28 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JF		06-11-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
TF		06-10-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60

Type	Qualifier	Distance
Building Overhang		9
Septic or Holding, or POWTS Tank		28

Comment:

Created On: 06-24-1992 Updated On: 08-19-2022 Review Status: