Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EQ548

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SHELDON SCHWANTES			Phone #: (414)548-0694
Mailing Address: 522 S GRAND AVE			
City: WAUKESHA	State: WI	Zip Code: 53186	
County: Waukesha	Co. Permit #:	Notification #:	Completed: 12-12-1991

Well Constructor (Business Name): ROSCHI BROS WELLDRLG @ PUMP INC	Lic. #: 435	Facility ID # (Public Wells):	
Address: 12665 W LISBON RD BROOKFIELD WI 53005-1824		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.7	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of GENESEE

Fire # (if avail.):

Street Address or Road Name and Number: W287 S3487 HWY D

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code:

NW or Govt Lot #	NW	Section	Township	Range
		13	6 N	18 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW CONSTRUCTION

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	86
6	86	179

Upper Enlarged Drillhole — Lower Open Bedrock

Yes Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	G	STONEY CLAY	Surface	7
		C	S	SANDY GRAVEL	7	43
		C	S	STONEY CLAY	43	69
		P		HARDPAN	69	86
		L		LIMESTONE	86	179

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK STEEL PIPE, WELDED JOINTS, 18.97LB. ASTM A531780 PSI VENEZUELA	Surface	86
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE DRILL FLUID	Surface	86	

9. Static Water Level
43 ft. below ground surface

10. Pump Test
Pumping level 58 ft. below surface
Pumping at 10 GP for 1.5 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
RR		12-12-1991
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
ERW		12-12-1991

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		90
Building Overhang		14
Foundation Drain to Clearwater		15
Septic or Holding, or POWTS Tank		53

Comment:

Created On: 01-23-1992 Updated On: 01-23-1992 Review Status: