

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EQ549		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner EPIC HOMES, INC.						Phone # (414)774-4424		1. Well Location				Fire # (if avail.)							
Mailing Address 2654 N 124TH ST						Town of TRENTON													
City WAUWATOSA						State WI		Zip Code 53226				Street Address or Road Name and Number 1544 MAPLE DALE DR							
County Washington		Co. Permit # W07410		Notification #		Completed 12-09-1991		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) ROSCHI BROS WELLDRLG @ PUMP INC				Lic. # 435		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.438 °N -88.1132 °W				Method Code GCD013					
Address 12665 W LISBON RD BROOKFIELD WI 53005-1824				Well Plan Approval # Approval Date (mm-dd-yyyy)		NE NW		Section 9		Township 11 N		Range 20 E							
						or Govt Lot #													
Hicap Permanent Well #				Common Well #		Specific Capacity 0.3				2. Well Type New Well of previous unique well # constructed in									
Reason for replaced or reconstructed well ? NEW CONSTRUCTION																			
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock													
8.75		Surface		155		Yes Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)													
6		155		199															
6. Casing, Liner, Screen						8. Geology													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		Geology Codes Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
6		BLACK STEEL PIPE, WELDED JOINTS, 18.97LB ASTM A531780 PSI VENEZUELA				Surface		155		C G		STONE CLAY		Surface 137					
										P		HARDPAN		137 155					
										L		LIMESTONE		155 199					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)											
7. Grout or Other Sealing Material Method												9. Static Water Level 45 ft. below ground surface				11. Well Is 12 in. above grade			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		10. Pump Test Pumping level 85 ft. below surface Pumping at 10 GP for 1.5 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes					
BENTONITE DRILL FLUID				Surface		155													
Filled & Sealed Well(s) as needed?												12. Notified Owner of need to fill & seal ?							
13. Constructor / Supervisory Driller												Lic #		Date Signed					
RR														12-09-1991					
Drill Rig Operator												Lic or Reg #		Date Signed					
ERW														12-09-1991					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		98	Foundation Drain to Clearwater		12
Building Overhang		10	Wastewater Sump		47
Clearwater Sump		13	Septic or Holding, or POWTS Tank		63

Comment:

Created On: 01-23-1992

Updated On: 07-05-2019

Review Status: