Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EQ550

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: STEVE JESMOK	Phone #
Mailing Address: 1737 N PALMER ST	
City: MILWAUKEE	State: WI — Zip Code: 53212
County: Ozaukee	Co. Permit #	Notification #	Completed: 12-16-1991
Well Constructor (Business Name): ROSCHI BROS WELLDRLG @ PUMP INC	Lic. #: 435	Facility ID # (Public Wells)
Address: 12665 W LISBON RD BROOKFIELD WI 53005-1824	Well Plan Approval #
	Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #	Specific Capacity: 1.2

1. Well Location

City of MEQUON

Fire # (if avail.)

Street Address or Road Name and Number: 11021 N SHERWOOD DR

Subdivision Name	Lot #	Block #
	00011	4

Latitude / Longitude in Decimal Degree (DD): 43.2185 °N -87.984 °W

Method Code: GCD013

NE	NE	Section	Township	Range
or Govt Lot #		27	9 N	21 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

NEW CONSTRUCTION

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	60
6	60	199

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C		CLAY	Surface	7
		C	G	STONEY CLAY	7	60
		L		LIMESTONE	60	199

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK STEEL PIPE WELDED JOINTS, 18.97LB. ASTM A531780 PSI SAWHILL	Surface	60
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

18 ft. below ground surface

10. Pump Test

Pumping level 28 ft. below surface

Pumping at 12 GP for 1.25 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE DRILL FLUID	Surface	60	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
RR		12-16-1991
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
ERW		12-16-1991

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		18	Foundation Drain to Clearwater		19
			Sewer - Building Sanitary		25

Comment:

Created On: 01-23-1992 Updated On: 07-15-2019 Review Status: