

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EQ726		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner PINE RIVER CONG. CHURCH						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address								Town of LEON													
City PINE RIVER						State WI		Zip Code 54965													
County Waushara		Co. Permit #		Notification #		Completed 03-25-1992		Subdivision Name				Lot # Block #									
Well Constructor (Business Name) JENKS, LARRY L				Lic. # 203		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code									
Address RT 2 BOX 1422 WILD ROSE WI 54984-9327				Well Plan Approval #		Approval Date (mm-dd-yyyy)		NW SE Section Township Range or Govt Lot # 4 19 N 12 E													
Hicap Permanent Well #		Common Well #		Specific Capacity 1.3		2. Well Type New Well of previous unique well # constructed in															
3. Well serves 1 # of CHURCH Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?		Reason for replaced or reconstructed well ? INSTALLED BATHROOMS													
								Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
2		Surface		63								Y		SAND @ GRAVEL		Surface		40			
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						C G		CLAY @ CLAY GRAVEL		40		54			
										W S		WATER BEARING SAND		54		63					
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		41 ft. below ground surface				12 in. above grade							
2		SAWHILL T @ C ASTM 589 3.75#				Surface		60		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 49 ft. below surface Pumping at 10 GP for 1.5 Hrs. Pumping Method ?											
1.25		X36X10 STAINLESS SCREEN				60		63													
7. Grout or Other Sealing Material Method														12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?							
										13. Constructor / Supervisory Driller				Lic #		Date Signed					
										LJ						04-22-1992					
										Drill Rig Operator				Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		4	Privy		60

Comment:

Created On: 06-09-1992

Updated On: 05-10-2004

Review Status: