Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EQ777

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ANN CHAPMAN	Phone #: (715)369-1606
Mailing Address: 209 HOMESTEAD	
City: RHINELANDER	State: WI Zip Code: 54501
County: Oneida	Co. Permit #:
Notification #:	Completed: 05-06-1992
Well Constructor (Business Name): JELINEK, DAVID C	Lic. #: 43
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: 2791 BAY DR RHINELANDER WI 54501-9465	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.8	

1. Well Location

Town of PELICAN				Fire # (if avail.): 209
Street Address or Road Name and Number: HOMESTEAD				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): °N °W				Method Code:
NW NW or Govt Lot #	Section: 8	Township: 36 N	Range: 9 E	

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: OLD WELL LOW PRODUCER

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	60

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y		SAND @ GRAVEL (DIRTY)	Surface	25
		M		SILT	25	50
	N	S		VERY FINE SAND (GREY)	50	55
T		S		CLEAN BROWN SAND	55	60

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	SAWHILL STEEL A53B 18.97#/FT WELDED	Surface	57
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	JOHNSON STAINLESS	57	60

7. Grout or Other Sealing Material

Method

9. Static Water Level

8 ft. below ground surface

10. Pump Test

Pumping level 20 ft. below surface

Pumping at 10 GP for 1 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DJ		05-12-1992
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ?

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		15	Septic or Holding, or POWTS Tank		100

Comment:

Created On: 06-03-1992 Updated On: 06-03-1992 Review Status: