Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EQ793

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PETE TENDERHOLT	Phone #: (715)367-1982
Mailing Address: 106 N BAIRD AVE	
City: RHINELANDER	State: WI Zip Code: 54501
County: Oneida	Co. Permit #:
Notification #:	Completed: 05-18-1992
Well Constructor (Business Name): JELINEK, DAVID C	Lic. #: 43
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: 2791 BAY DR RHINELANDER WI 54501-9465	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0	

1. Well Location

Fire # (if avail.):

Town of PINE LAKE

Street Address or Road Name and Number: FOREST LN

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code:

SW SE or Govt Lot #:	Section: 19	Township: 37 N	Range: 9 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?: NEW HOME

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	40
6	40	240

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 8in. dia
- Yes — Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	Q	Y	G	CAVING SAND, GRAVEL @ BOULDERS	Surface	32
		Q		GRANITE BEDROCK	32	240

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	SAWHILL STEEL A53B 18.97#/FT WELDED	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method CONDUCTOR PIPE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CEMENT GROUT	Surface	40	5

9. Static Water Level

15 ft. below ground surface

10. Pump Test

Pumping level 220 ft. below surface

Pumping at 3 GP for 20 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DJ		06-10-1992
Drill Rig Operator	Lic or Reg #	Date Signed
DJ		06-10-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		63

Type	Qualifier	Distance
Building Overhang		25
Septic or Holding, or POWTS Tank		80

Comment:

Rehab Type	Rehab Date	Result Text
Hydrofracture		DRY HOLE BEFORE

Created On: 06-29-1992 Updated On: 10-15-2026 Review Status: