

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EQ793		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner PETE TENDERHOLT						Phone # (715)367-1982		1. Well Location				Fire # (if avail.)							
Mailing Address 106 N BAIRD AVE						Town of PINE LAKE						Street Address or Road Name and Number FOREST LN							
City RHINELANDER				State WI		Zip Code 54501													
County Oneida		Co. Permit #		Notification #		Completed 05-18-1992		Subdivision Name			Lot #		Block #						
Well Constructor (Business Name) JELINEK, DAVID C				Lic. # 43		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code								
Address 2791 BAY DR RHINELANDER WI 54501-9465				Well Plan Approval #		SW SE		Section 19		Township 37 N		Range 9 E							
				Approval Date (mm-dd-yyyy)		or Govt Lot #		Township 37 N		Range 9 E									
Hicap Permanent Well #		Common Well #		Specific Capacity		2. Well Type New Well													
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		of previous unique well # constructed in											
						Hicap Property ? No		Reason for replaced or reconstructed well ? NEW HOME											
Heat Exchange ___ # of drillholes						Hicap Potable ?		Construction Type Drilled											
						Hicap Potable ?		Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8		Surface		40		Rotary - Mud Circulation		Rotary - Air		Q Y G		CAVING SAND, GRAVEL @ BOULDERS		Surface		32			
6		40		240		Rotary - Air & Foam		Drill-Through Casing Hammer		Q		GRANITE BEDROCK		32		240			
Yes		Rotary - Air & Foam		Reverse Rotary		Cable-tool Bit ___ in. dia...		Dual Rotary		Temp. Outer Casing 8in. dia Removed? ___ depth ft. (If NO explain on back side)									
Yes		Temp. Outer Casing 8in. dia		Yes		Cable-tool Bit ___ in. dia...		Dual Rotary											
Yes		Temp. Outer Casing 8in. dia		Yes		Cable-tool Bit ___ in. dia...		Dual Rotary											
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		15 ft. below ground surface				14 in. above grade					
6		SAWHILL STEEL A53B 18.97#/FT WELDED				Surface		40		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 220 ft. below surface				Disinfected ? Yes					
6		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at 3 GP for 20 Hrs.				Capped ? Yes					
6		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping Method ?				Filled & Sealed Well(s) as needed? Yes					
6		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping Method ?									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method CONDUCTOR PIPE												Filled & Sealed Well(s) as needed? Yes							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed			
CEMENT GROUT				Surface		40		5		DJ				06-10-1992					
CEMENT GROUT				Surface		40		5		Drill Rig Operator				Lic or Reg #		Date Signed			
CEMENT GROUT				Surface		40		5		DJ				06-10-1992					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		25	Septic or Holding, or POWTS Tank		80
			POWTS dispersal component (soil absorption unit or mound)		63

Comment:

Rehab Type	Rehab Date	Result Text
Hydrofracture		DRY HOLE BEFORE

Created On: 06-29-1992

Updated On: 06-29-1992

Review Status: