

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EQ859		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner WALTER WICKESBURY						Phone # (414)984-3423		1. Well Location				Fire # (if avail.)		
Mailing Address N6631 STATE RD						Town of BLACK CREEK						Street Address or Road Name and Number		
City BLACK CREEK				State WI		Zip Code 54106								
County Outagamie		Co. Permit #		Notification #		Completed 04-10-1992		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) JONES, NOBLE F				Lic. # 640		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code		
Address RT 2 10460 HWY A SURING WI 54174-9802				Well Plan Approval #		Approval Date (mm-dd-yyyy)		°N		°W		NE SE Section Township Range or Govt Lot # 7 23 N 17 E		
								2. Well Type Replacement						
Hicap Permanent Well #				Common Well #		Specific Capacity 0.1		Reason for replaced or reconstructed well ? OLD WELL LOW CAPACITY						
3. Well serves # of Private, potable				Hicap Well ? No		Hicap Property ? No		Construction Type Drilled						
Heat Exchange ___ # of drillholes				Hicap Potable ?										
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock											
10 Surface 20			Yes Rotary - Mud Circulation											
6 20 385			Rotary - Air											
			Rotary - Air & Foam											
			Drill-Through Casing Hammer											
			Reverse Rotary											
			Cable-tool Bit ___ in. dia...											
			Dual Rotary											
			Temp. Outer Casing ___ in. dia											
			Removed? ___ depth ft. (If NO explain on back side)											
8. Geology														
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
V X				SAND CLAY MIX - NON-CAVING				Surface		60				
N S C				FINE STICKY SAND WITH CLAY				60		75				
R C				RED CLAY				75		378				
S				SAND				378		385				
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 20 ft. below ground surface				
6		ASTM A-53 18.97# SAWHILL STEEL, WELDED				Surface		381						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test Pumping level 200 ft. below surface Pumping at 25 GP for 1 Hrs. Pumping Method ?				
5		STAINLESS STEEL - TELESCOPING				381		385						
7. Grout or Other Sealing Material														
Method UD CIRCULATION														
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement						
DRILLING MUD				Surface		20		11. Well Is 12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes						
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? IN USE														
13. Constructor / Supervisory Driller								Lic #		Date Signed				
NJ										05-01-1992				
Drill Rig Operator								Lic or Reg #		Date Signed				

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Animal Barn Pen		120
Building Drain - Sanitary		110	Silo/Storage Tube		150
Building Overhang		100	Animal Yard - Include Hutches		120
Nonconforming Pit or Alcove		125	Barn Gutter		120
Sewer - Building Sanitary		100	Septic or Holding, or POWTS Tank		75

Comment:

Created On: 06-01-1992

Updated On: 06-01-1992

Review Status: