Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EQ860

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DENNIS ROEHL			Phone #: (715)823-4014
Mailing Address: RT 3			
City: EMBARRASS	State: WI	Zip Code: 54933	
County: Waupaca	Co. Permit #:	Notification #:	Completed: 05-05-1992

Well Constructor (Business Name): JONES, NOBLE F	Lic. #: 640	Facility ID # (Public Wells):	
Address: RT 2 10460 HWY A SURING WI 54174-9802		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.8	

1. Well Location

Town of MATTESON

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code:
NW NW or Govt Lot #:	Section: 10	Township: 25 N	Range: 15 E

2. Well Type New Well

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: FOR NEW HOME-NOT STARTED

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	130

Upper Enlarged Drillhole — Lower Open Bedrock

Yes Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	Q	S		SAND CAVING	Surface	15
		X		SAND CLAY MIX	15	75
		C		CLAY	75	123
		S		SAND	123	130

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A-53 18.97# SAWHILL STEEL-WELDED	Surface	127
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	STAINLESS STEEL-TELESCOPING	127	130

7. Grout or Other Sealing Material

Method MUD CIRC

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD	Surface	20	

9. Static Water Level

22 ft. below ground surface

10. Pump Test

Pumping level 100 ft. below surface

Pumping at 60 GP for 0.5 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
NJ		05-12-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
YJ		05-12-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 06-03-1992 Updated On: 06-03-1992 Review Status: