

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EQ860		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner DENNIS ROEHL						Phone # (715)823-4014		1. Well Location				Fire # (if avail.)			
Mailing Address RT 3						Town of MATTESON									
City EMBARRASS						State WI		Zip Code 54933							
County Waupaca		Co. Permit #		Notification #		Completed 05-05-1992		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) JONES, NOBLE F				Lic. # 640		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code			
Address RT 2 10460 HWY A SURING WI 54174-9802				Well Plan Approval #		Approval Date (mm-dd-yyyy)		°N °W		Range					
								NW NW Section Township Range or Govt Lot # 10 25 N 15 E							
Hicap Permanent Well #		Common Well #		Specific Capacity 0.8		2. Well Type New Well						of previous unique well # constructed in			
Reason for replaced or reconstructed well ?				FOR NEW HOME-NOT STARTED											
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No		Construction Type Drilled							
Heat Exchange ___ # of drillholes				Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock									
10		Surface		20		Yes Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
6		20		130											
8. Geology						Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)					
		Q S		SAND CAVING		Surface		15							
		X		SAND CLAY MIX		15		75							
		C		CLAY		75		123							
		S		SAND		123		130							
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)		22 ft. below ground surface				12 in. above grade			
6		ASTM A-53 18.97# SAWHILL STEEL-WELDED				Surface		127		10. Pump Test					
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)		Pumping level 100 ft. below surface				Developed ? Yes			
5		STAINLESS STEEL-TELESCOPING				127		130		Pumping at 60 GP for 0.5 Hrs.				Disinfected ? Yes	
7. Grout or Other Sealing Material						Pumping Method ?				Capped ? Yes					
Method MUD CIRC						12. Notified Owner of need to fill & seal ?									
Kind of Sealing Material		From (ft.) To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?									
DRILLING MUD		Surface		20											
13. Constructor / Supervisory Driller						Lic #		Date Signed							
NJ								05-12-1992							
Drill Rig Operator						Lic or Reg #		Date Signed							
YJ								05-12-1992							

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 06-03-1992

Updated On: 06-03-1992

Review Status: