Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EQ971

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KEVIN PETERS	Phone #
Mailing Address: 11601 W BROWN DEER	
City: MILWAUKEE	State: WI — Zip Code: 53224
County: Washington	Co. Permit #	Notification #	Completed: 03-04-1992
Well Constructor (Business Name): GROTH, HOWARD H	Lic. #: 651	Facility ID # (Public Wells)
Address: W69 N949 WASHINGTON CEDARBURG WI 53012	Well Plan Approval #	Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.8

1. Well Location

Town of POLK

Fire # (if avail.)

Street Address or Road Name and Number: 3525 CUMBERLAND TRL

Subdivision Name	Lot #	Block #
LEXINGTON VILLAGE	00057	

Latitude / Longitude in Decimal Degree (DD)	Method Code
43.3179 °N -88.2384 °W	GCD013

SW	NW	Section	Township	Range
or Govt Lot #		22	10 N	19 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	112

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		G	S	GRAVEL @ SAND	Surface	28
		G		GRAVEL	28	45
		C	S	SANDY CLAY	45	101
		G		GRAVEL	101	112

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	18.97#, ASTM, A-53, L.T.V., P.E.	Surface	112
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

60 ft. below ground surface

10. Pump Test

Pumping level 75 ft. below surface

Pumping at 12 GP for 2 Hrs.

Pumping Method ?

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
HG		03-06-1992
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		85
Building Drain - Sanitary		40
Building Overhang		10
Clearwater Sump		27

Type	Qualifier	Distance
Downspout/Yard Hydrant		10
Foundation Drain to Clearwater		11
Wastewater Sump		42
Sewer - Building Sanitary		58
Septic or Holding, or POWTS Tank		70

Comment:

Created On: 04-24-1992 Updated On: 07-08-2019 Review Status: