Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EQ972

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: TOMAS BALL			Phone #
Mailing Address: 388 PIONEER RD			
City: RICHFIELD	State: WI	Zip Code: 53076	
County: Washington	Co. Permit #: W07414	Notification #	Completed: 03-12-1992

Well Constructor (Business Name): GROTH, HOWARD H	Lic. #: 651	Facility ID # (Public Wells)	
Address: W69 N949 WASHINGTON CEDARBURG WI 53012		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.7	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of RICHFIELD

Fire # (if avail.)

Street Address or Road Name and Number: 2365 BALL DR

Subdivision Name: HEAVENLY VIEW	Lot #: 00018	Block #

Latitude / Longitude in Decimal Degree (DD): 43.2761 °N -88.2366 °W			Method Code: GCD013
SW NW or Govt Lot #	Section: 3	Township: 9 N	Range: 19 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	220

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		G	G	GRAVEL @ STONES	Surface	132
		C		CLAY	132	147
		C	S	SANDY CLAY	147	193
		C		CLAY	193	201
		L		LIMEROCK	201	220

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	18.97#, ASTM, A-53, LTV P.E.	Surface	201
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method

9. Static Water Level
89 ft. below ground surface

10. Pump Test
Pumping level 110 ft. below surface
Pumping at 15 GP for 2 Hrs.
Pumping Method ?

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
HG		03-23-1992
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80
Building Drain - Sanitary		65
Building Overhang		14
Foundation Drain to Clearwater		14
Wastewater Sump		12
Sewer - Building Sanitary		63
Septic or Holding, or POWTS Tank		50

Comment:

Created On: 04-27-1992 Updated On: 07-05-2019 Review Status: