Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ER243

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SCHERRER-STROHM, INC	Phone #: (414)763-9668
Mailing Address: PO BOX 179 249 ADAMS	
City: BURLINGTON	State: WI — Zip Code: 53105
County: Racine	Co. Permit #:	Notification #:	Completed: 05-18-1992
Well Constructor (Business Name): GOHLKE, WILLIAM J	Lic. #: 693	Facility ID # (Public Wells):
Address: 19400 38TH ST BRISTOL WI 53104	Well Plan Approval #:	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 4

1. Well Location

Town of BURLINGTON

Fire # (if avail.):

Street Address or Road Name and Number: BROWNS LAKE DR

Subdivision Name	Lot #	Block #
	00792	

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code:

NW or Govt Lot #	NW	Section	Township	Range
		27	3 N	19 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	83

Upper Enlarged Drillhole / Lower Open Bedrock

Yes Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		S		SANDY BROWN	Surface	7
		G		GRAVEL	7	12
		P		HARD PAN	12	62
		G	P	GRAVEL HARD PAN	62	71
		G	S	GRAVEL/SAND	71	83

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	ID NEW PVC 200 PSI CERTAIN TEEP F480 NSF WC PWD2241 1120 SDR 21	Surface	78
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	PVC SLOTTED	78	83

9. Static Water Level

30 ft. below ground surface

10. Pump Test

Pumping level 35 ft. below surface

Pumping at 20 GP for 4 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CUTTINGS-HOLE PLUG-QUICK GEL	Surface	78	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
WG		05-27-1992
Drill Rig Operator	Lic or Reg #	Date Signed
DG		05-27-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		15	Collector Sewer - San or Storm		100
			Sewer - Building Sanitary		40

Comment:

Created On: 06-19-1992 Updated On: 06-19-1992 Review Status: