

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ER243		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner SCHERRER-STROHM, INC						Phone # (414)763-9668		1. Well Location				Fire # (if avail.)									
Mailing Address PO BOX 179 249 ADAMS						Town of BURLINGTON															
City BURLINGTON						State WI		Zip Code 53105													
County Racine		Co. Permit #		Notification #		Completed 05-18-1992		Subdivision Name				Lot # 00792									
Well Constructor (Business Name) GOHLKE, WILLIAM J				Lic. # 693		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code									
Address 19400 38TH ST BRISTOL WI 53104				Well Plan Approval #		Approval Date (mm-dd-yyyy)		°N °W		Range											
Hicap Permanent Well #		Common Well #		Specific Capacity 4		NW NW Section Township Range or Govt Lot # 27 3 N 19 E		2. Well Type New Well													
3. Well serves 1 # of Private, potable						Hicap Well ? No		of previous unique well # constructed in													
Heat Exchange ___ # of drillholes						Hicap Property ? No		Reason for replaced or reconstructed well ?													
						Hicap Potable ?		Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
9		Surface		83		Yes Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						T S		SANDY BROWN		Surface		7			
												G		GRAVEL		7		12			
												P		HARD PAN		12		62			
												G P		GRAVEL HARD PAN		62		71			
												G S		GRAVEL/SAND		71		83			
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		30 ft. below ground surface				12 in. above grade							
5		ID NEW PVC 200 PSI CERTAIN TEEP F480 NSF WC PWD2241 1120 SDR 21				Surface		78		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 35 ft. below surface				Disinfected ? Yes							
5		PVC SLOTTED				78		83		Pumping at 20 GP for 4 Hrs.				Capped ? Yes							
7. Grout or Other Sealing Material										12. Notified Owner of need to fill & seal ?											
Method GRAVITY										Filled & Sealed Well(s) as needed? Yes											
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed					
CUTTINGS-HOLE PLUG-QUICK GEL				Surface		78				WG						05-27-1992					
										Drill Rig Operator				Lic or Reg #		Date Signed					
										DG						05-27-1992					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		15	Collector Sewer - San or Storm		100
			Sewer - Building Sanitary		40

Comment:

Created On: 06-19-1992

Updated On: 06-19-1992

Review Status: