Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ER435

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LOUIS HEINZE	Phone #
Mailing Address: W806 HWY U	
City: BANGOR	State: WI — Zip Code: 54614
County: La Crosse	Co. Permit #: W06333 — Notification # — Completed: 04-29-1992
Well Constructor (Business Name): STUHR, RANDY C	Lic. #: 58 — Facility ID # (Public Wells)
Address: 624 AMY DR, HOLMEN WI 54636	Well Plan Approval # — Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well # — Specific Capacity: 1.7

1. Well Location

Town of BURNS	Fire # (if avail.): W806
Street Address or Road Name and Number: HWY U	
Subdivision Name	Lot # — Block #
Latitude / Longitude in Decimal Degree (DD): °N °W	Method Code
SW SW or Govt Lot # — Section: 35 — Township: 17 N — Range: 5 W	

2. Well Type Replacement

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?: PLUGGED SANDPONT

Construction Type: Drilled

3. Well serves 1 # of HOUSE

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	40

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 4in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	CLAY	Surface	6
Y	SAND @ GRAVEL	6	35
T S	BROWN SAND	35	43

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	ASTM A-589 T@C .237 WALL 11.00#/FT REAMED @DRIFTED TYPE II SAWHILL U.S.A.	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3	STAINLESS STEEL	40	43

9. Static Water Level

24 ft. below ground surface

10. Pump Test

Pumping level 33 ft. below surface

Pumping at 15 GP for 4 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NATIVE MATERIAL	Surface	40	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RCS		06-01-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RCS		06-01-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80
Building Drain - Sanitary		20

Type	Qualifier	Distance
Building Overhang		3
Sewer - Building Sanitary		20
Septic or Holding, or POWTS Tank		60

Comment:

Created On: 06-19-1992 Updated On: 06-19-1992 Review Status: