Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ER436

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ALLEN JERNIGEN			Phone #
Mailing Address: HWY W			
City: HOLMEN	State: WI	Zip Code: 54636	
County: La Crosse	Co. Permit #: W05736	Notification #	Completed: 05-15-1992

Well Constructor (Business Name): STUHR, RANDY C	Lic. #: 58	Facility ID # (Public Wells)
Address: 624 AMY DR HOLMEN WI 54636		Well Plan Approval #
		Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.8

1. Well Location

Town of ONALASKA

Fire # (if avail.)

Street Address or Road Name and Number: HWY W

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

NE	SE	Section	Township	Range
or Govt Lot #		2	17 N	7 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: WATER SUPPLY

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	105
6	105	165

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....
Rotary - Air .....
Yes Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		C	U	BROWN CLAY @ MUD	Surface	45
T		N		BROWN SANDSTONE	45	100
U		H		BLUE SHALE	100	115
G		N		GREY SANDSTONE FINE	115	165

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A53 B P.E. 280 WALL 18.97#/FT SAWHILL U.S.A.	Surface	105
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

72 ft. below ground surface

10. Pump Test

Pumping level 87 ft. below surface

Pumping at 12 GP for 4 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	105	34

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RCS		06-01-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RCS		06-01-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80
Building Drain - Sanitary		40

Type	Qualifier	Distance
Building Overhang		20
Sewer - Building Sanitary		40
Septic or Holding, or POWTS Tank		60

Comment:

Created On: 06-19-1992 Updated On: 06-19-1992 Review Status: