Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ER437

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FRANCIS BENZING			Phone #
Mailing Address: RT 1 HWY B			
City: SPARTA	State: WI	Zip Code: 54656	
County: Monroe	Co. Permit #	Notification #	Completed: 05-26-1992

Well Constructor (Business Name): STUHR, RANDY C	Lic. #: 58	Facility ID # (Public Wells)	
Address: 624 AMY DR HOLMEN WI 54636		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 1.5	

1. Well Location

Fire # (if avail.)

Town of SPARTA

Street Address or Road Name and Number: HWY B

Subdivision Name	Lot #	Block #	
Latitude / Longitude in Decimal Degree (DD): °N °W		Method Code	
SW NE or Govt Lot #:	Section: 2	Township: 17 N	Range: 4 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: WATER SUPPLY

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	71
6	71	85

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Yes — Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C		CLAY	Surface	6
		S		SAND	6	20
T		N		BROWN SANDSTONE	20	60
R		N		RED SANDSTONE	60	68
T		N		BROWN-YELLOW SANDSTONE	68	85

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM-A53 B P.E. .280 WALL 18.97#/FT SAWHILL U.S.A.	Surface	71
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

25 ft. below ground surface

10. Pump Test

Pumping level 33 ft. below surface

Pumping at 12 GP for 4 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	71	24

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RCS		06-02-1992
Drill Rig Operator	Lic or Reg #	Date Signed
RCS		06-02-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75
Building Drain - Sanitary		30

Type	Qualifier	Distance
Building Overhang		6
Sewer - Building Sanitary		30
Septic or Holding, or POWTS Tank		55

Comment:

Created On: 06-19-1992 Updated On: 06-19-1992 Review Status: