

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ER613		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner LARRY DOBBE						Phone # (608)221-3804		1. Well Location				Fire # (if avail.)			
Mailing Address 3101 MEIER RD						Town of DEKORRA						Street Address or Road Name and Number W 10691 WILDWOOD WAY			
City MADISON				State WI		Zip Code 53704									
County Columbia		Co. Permit #		Notification #		Completed 06-01-1992		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) BERKHOLTZ, RICHARD				Lic. # 3		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.4014 °N -89.5309 °W				Method Code GCD013	
Address 6400 LAKE RD WINDSOR WI 53598-9717				Well Plan Approval #		NE SW		Section 27		Township 11 N		Range 8 E			
				Approval Date (mm-dd-yyyy)				or Govt Lot #		27		11 N		8 E	
Hicap Permanent Well #				Common Well #		Specific Capacity 0.7				2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? NEW CONSTRUCTION Construction Type Drilled					
3. Well serves 1 # of				Hicap Well ? No											
Private, potable				Hicap Property ? No											
Heat Exchange ___ # of drillholes				Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
8.75 Surface 42			Yes Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)												
6 42 345															
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
C CLAY				Surface				18							
N SANDSTONE				18				62							
E N GREEN SANDSTONE				62				73							
T N TAN SANDSTONE				73				345							
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		STD. STEEL PE NEW 18.97LBS ASTM-53 SAWHILL GRADE B				Surface		42							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
6		STD. STEEL PE NEW 18.97LBS ASTM-53 SAWHILL GRADE B				Surface		42							
7. Grout or Other Sealing Material															
Method PRESSURE CEMENT															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
NEAT CEMENT				Surface		42		6							
9. Static Water Level															
220 ft. below ground surface															
10. Pump Test															
Pumping level 250 ft. below surface															
Pumping at 20 GP for 1 Hrs.															
Pumping Method ?															
11. Well Is															
14 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? NONE															
13. Constructor / Supervisory Driller															
Lic #								Date Signed							
RB								06-03-1992							
Drill Rig Operator								Lic or Reg #							
RCB								06-03-1992							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Downspout/Yard Hydrant		14
Building Drain - Sanitary		19	Foundation Drain to Clearwater		13
Building Overhang		13	Sewer - Building Sanitary		30
			Septic or Holding, or POWTS Tank		30

Comment:

Created On: 06-24-1992

Updated On: 12-16-2020

Review Status: