

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ER682		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner DON BELMAN HOMES						Phone # (414)544-4648		1. Well Location				Fire # (if avail.)							
Mailing Address W227 S4130 CONCORD						Town of MUKWONAGO						Street Address or Road Name and Number							
City WAUKESHA						State WI		Zip Code 53186				S76 W32387 HAWTHORN CIR							
County Waukesha		Co. Permit #		Notification #		Completed 04-24-1992		Subdivision Name MAYFLOWER HILLS				Lot # 00026		Block #					
Well Constructor (Business Name) LAHR, PATRICK J				Lic. # 187		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code							
						Well Plan Approval #		°N °W											
Address N48 W14784 LISBON RD MENOMONEE FALLS WI 53051						Approval Date (mm-dd-yyyy)		NW SE Section Township Range or Govt Lot # 8 5 N 18 E											
Hicap Permanent Well #		Common Well #		Specific Capacity 0.7				2. Well Type New Well				of previous unique well # constructed in							
								Reason for replaced or reconstructed well ?				NEW HOME							
3. Well serves 1 # of Private, potable				Hicap Well ? No															
Heat Exchange ___ # of drillholes				Hicap Property ? No															
				Hicap Potable ?				Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
10		Surface		20								CLAY @ GRAVEL		Surface		105			
6		20		262		Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						HARD PAN		105		110			
												LIMESTONE		110		262			
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		115 ft. below ground surface				12 in. above grade					
6		P/E PIPE ASTM A-53 GR B LTV STEEL, 18.97#/FT WELD				Surface		110		10. Pump Test				Developed ? Yes					
										Pumping level 130 ft. below surface				Disinfected ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at 11 GP for 1 Hrs.				Capped ? Yes					
										Pumping Method ?									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method												Filled & Sealed Well(s) as needed?							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement											
BENTONITE				Surface		20													
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												PL						04-28-1992	
												Drill Rig Operator				Lic or Reg #		Date Signed	
												RP						04-28-1992	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Downspout/Yard Hydrant		20
Building Overhang		15	Foundation Drain to Clearwater		46
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 06-01-1992

Updated On: 06-01-1992

Review Status: