

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ER683		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner DON BELMAN HOMES						Phone # (414)544-4648		1. Well Location				Fire # (if avail.)											
Mailing Address W227 S4130 CONCORD						Town of MUKWONAGO																	
City WAUKESHA						State WI		Zip Code 53186				Street Address or Road Name and Number W330 S7990 COUNTRY LN											
County Waukesha		Co. Permit #		Notification #		Completed 04-27-1992		Subdivision Name NORMANDY GREEN				Lot # 00007		Block #									
Well Constructor (Business Name) LAHR, PATRICK J				Lic. # 187		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 42.8995 °N -88.4062 °W				Method Code GCD013											
Address N48 W14784 LISBON RD MENOMONEE FALLS WI 53051				Well Plan Approval #		Approval Date (mm-dd-yyyy)		NE NE		Section Township		Range											
								or Govt Lot # 18		5 N		18 E											
Hicap Permanent Well #				Common Well #		Specific Capacity 0.3		2. Well Type New Well															
Reason for replaced or reconstructed well ? NEW HOME																							
3. Well serves 1 # of				Hicap Well ? No		Hicap Property ? No		Construction Type Drilled															
Private, potable				Hicap Potable ?																			
Heat Exchange ___ # of drillholes																							
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
10		Surface		20		Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						G		GRAVEL		Surface		57					
6		20		80								L		LIMESTONE		57		80					
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		20 ft. below ground surface				12 in. above grade									
6		P/E PIPE ASTM A-53 GR B LTV STEEL, 18.97#/FT WELD				Surface		57		10. Pump Test				Developed ? Yes									
										Pumping level 75 ft. below surface				Disinfected ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at 15 GP for 1 Hrs.				Capped ? Yes									
										Pumping Method ?													
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?									
Method														Filled & Sealed Well(s) as needed?									
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed							
BENTONITE				Surface		20				PL						04-28-1992							
														Drill Rig Operator				Lic or Reg #		Date Signed			
														RP						04-28-1992			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Downspout/Yard Hydrant		16
Building Overhang		13	Foundation Drain to Clearwater		15
Clearwater Sump		19	Septic or Holding, or POWTS Tank		60

Comment:

Created On: 06-01-1992

Updated On: 07-12-2019

Review Status: