

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ER706		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner CHARLES APITZ						Phone # (414)989-1359		1. Well Location				Fire # (if avail.)							
Mailing Address W4484 HWY 10						Town of HARRISON						Street Address or Road Name and Number W4484 HWY 10							
City MENASHA				State WI		Zip Code 54952													
County Calumet		Co. Permit #		Notification #		Completed 04-23-1992		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) LEFEBER, DENNIS R				Lic. # 434		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.2136 °N -88.2628 °W				Method Code GCD013					
Address W2593 CNTY O MALONE WI 53049-1242				Well Plan Approval #				SW SW Section Township Range or Govt Lot # 8 20 N 19 E		2. Well Type New Well LY095 replaces this well of previous unique well # constructed in Reason for replaced or reconstructed well ? SHARED WELL WITH NEIGHBOR									
				Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #				Common Well #		Specific Capacity 0.7				Construction Type Drilled									
3. Well serves 1 # of				Hicap Well ? No															
Private, potable				Hicap Property ? No															
Heat Exchange ___ # of drillholes				Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock									Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)			
10 Surface 20			Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 10in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									R I TOP SOIL Surface 2		C RED CLAY 2 140		P HARD PAN 140 160		L LIMESTONE 160 175	
6 20 175																			
6																			
6																			
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		140 ft. below ground surface				16 in. ____ grade					
6		P.E. NEW STEEL WELDED JOINTS #18.97 ASTM A53 GRADEB SAWHILL STEEL INC				Surface		160		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 155 ft. below surface				Disinfected ? Yes					
6		6				6		6		Pumping at 10 GP for 24 Hrs.				Capped ? Yes					
6		6				6		6		Pumping Method ?				12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?					
6		6				6		6		6									
7. Grout or Other Sealing Material												13. Constructor / Supervisory Driller				Lic #		Date Signed	
Method												DL				04-27-1992		04-27-1992	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Drill Rig Operator				Lic or Reg #		Date Signed			
RED CLAY PUBBLING				Surface		20		20		LL				04-27-1992		04-27-1992			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		65	Building Overhang		16
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 06-24-1992

Updated On: 08-13-2019

Review Status: