Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ER709

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WAYNE BINNING			Phone #: (414)583-3519
Mailing Address: W7247 HWY Y			
City: BROWNSVILLE	State: WI	Zip Code: 53006	
County: Fond du Lac	Co. Permit #:	Notification #:	Completed: 05-14-1992

Well Constructor (Business Name): LEFEBER, DENNIS R	Lic. #: 434	Facility ID # (Public Wells):	
Address: W2593 CNTY O MALONE WI 53049-1242		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.1	

1. Well Location

Fire # (if avail.):

Town of OAKFIELD

Street Address or Road Name and Number: CO TRK B

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): 43.64764 °N -88.59194 °W				Method Code: GPS008
SE SW or Govt Lot #:	Section: 28	Township: 14 N	Range: 16 E	

2. Well Type New Well

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	160

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
I	TOP SOIL	Surface	2
Y	SAND @ GRAVEL	2	21
P	HARDPAN	21	36
H	SHALE	36	140
L	LIMESTONE	140	160

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	P.E. NEW STEEL WELDED JOINTS #18.97 ASTM A53 GRADEB SAWHILL STEEL INC	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

20 ft. below ground surface

10. Pump Test

Pumping level 80 ft. below surface

Pumping at 7 GP for 6 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DL		06-02-1992
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ?

Type	Qualifier	Distance
Building Overhang		40

Comment:

Created On: 06-24-1992 Updated On: 08-19-2022 Review Status: