Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ER728

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ROBERT KOMES	Phone #: (414)563-2839
Mailing Address: 620 N 4TH ST	
City: FORT ATKINSON	State: WI — Zip Code: 53538
County: Jefferson	Co. Permit #: — Notification #: — Completed: 03-19-1992
Well Constructor (Business Name): WERNER, J F	Lic. #: 76 — Facility ID # (Public Wells):
Address: RT 1 JEFFERSON WI 53549-9801	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #: — Common Well #: — Specific Capacity: 0.7	

1. Well Location

Fire # (if avail.):

Town of KOSHKONONG

Street Address or Road Name and Number: BRIAR LN

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

NE SW or Govt Lot #: — Section: 16 — Township: 5 N — Range: 14 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: NEW HOME CONSTRUCTION

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	250

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y		S		YELLOW SAND	Surface	70
G		C	S	GRAY SANDY CLAY	70	86
G		S		GRAY SAND	86	214
		G		GRAVEL	214	219
Y		N		YELLOW SANDSTONE	219	250

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	T@C STEEL PIPE ASTM A53 VALLEY STEEL CORP 19.45LBS/FT HYDRO TESTED 1780 PSI	Surface	225
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

20 ft. below ground surface

10. Pump Test

Pumping level 45 ft. below surface

Pumping at 18 GP for 3 Hrs.

Pumping Method ?

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
JW		03-19-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MJ		03-19-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		12

Comment:

Created On: 06-03-1992 Updated On: 06-03-1992 Review Status: