

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ER736		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner CHARLES UNTZ						Phone # (414)648-8741		1. Well Location				Fire # (if avail.)					
Mailing Address N5816 HWY 89						Town of LAKE MILLS											
City LAKE MILLS						State WI		Zip Code 53551									
County Jefferson		Co. Permit #		Notification #		Completed 05-14-1992		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) WERNER, J F				Lic. # 76		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.05799 °N -88.9024 °W				Method Code GPS008					
Address RT 1 JEFFERSON WI 53549-9801				Well Plan Approval #		Approval Date (mm-dd-yyyy)		NW SE		Section 24		Township 7 N		Range 13 E			
								or Govt Lot #									
Hicap Permanent Well #				Common Well #		Specific Capacity 2.2		2. Well Type New Well									
								of previous unique well # constructed in									
								Reason for replaced or reconstructed well ?									
								NEW HOME CONSTRUCTION									
3. Well serves 1 # of				Hicap Well ? No				Construction Type Drilled									
Private, potable				Hicap Property ? No													
Heat Exchange ___ # of drillholes				Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.) 6		From (ft.) Surface		To (ft.) 147		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology							
						Rotary - Mud Circulation				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)			
						Rotary - Air				I		TOP SOIL		Surface 5			
						Rotary - Air & Foam				S		SAND		5 17			
						Drill-Through Casing Hammer				Y C S		YELLOW SANDY CLAY		17 75			
						Reverse Rotary				Y S		YELLOW SAND		75 115			
						Cable-tool Bit ___ in. dia...				I N		WHITE SANDSTONE		115 147			
						Dual Rotary											
						Temp. Outer Casing ___ in. dia											
						Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is			
Dia. (in.) 6		Material, Weight, Specification T@C STEEL PIPE ASTM A53 VALLEY STEEL CORP 19.45LBSFT HYDRO TESTED 1780 PSI				From (ft.) Surface		To (ft.) 117		16 ft. below ground surface		18 in. above grade					
										10. Pump Test		Developed ? Yes					
										Pumping level 25 ft. below surface		Disinfected ? Yes					
										Pumping at 20 GP for 2.5 Hrs.		Capped ? Yes					
										Pumping Method ?							
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?					
Method												Filled & Sealed Well(s) as needed?					
												13. Constructor / Supervisory Driller		Lic #		Date Signed	
												JW				05-15-1992	
												Drill Rig Operator		Lic or Reg #		Date Signed	
												MJ				05-15-1992	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		11

Comment:

Created On: 06-09-1992

Updated On: 08-19-2022

Review Status: