Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ES203

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: PETER MOTL			Phone #: (715)726-2222
Mailing Address: 5300 MARS DR			
City: CHIPPEWA FALLS	State: WI	Zip Code: 54729	
County: Chippewa	Co. Permit #: W06130	Notification #	Completed: 04-09-1992

Well Constructor (Business Name): WETTSTEIN, MICHAEL J	Lic. #: 206	Facility ID # (Public Wells)	
Address: RT 2 BOX 130C EAU CLAIRE WI 54703-9802		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of LAFAYETTE

Fire # (if avail.)

Street Address or Road Name and Number
STILLSON RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)
°N °W

Method Code

SE	SW	Section	Township	Range
or Govt Lot #		7	28 N	7 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	42
6	42	80

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Yes Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes Temp. Outer Casing 10in. dia
- Yes Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		C		BROWN CLAY	Surface	10
T		N		LIGHT BROWN SANDROCK	10	80

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STEEL THREADED @ CUPPLED 20 LBS PER FT ASTMA53 B 1780 PSI VALLEY STEEL PIPE	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method PRESSURE TREMIE LINE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLEAR CEMENT @ WATER	Surface	42	12

9. Static Water Level
50 ft. below ground surface

10. Pump Test
Pumping level 50 ft. below surface
Pumping at 18 GP for 3 Hrs.
Pumping Method ?

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
MW		05-13-1992
Drill Rig Operator	Lic or Reg #	Date Signed
MW		05-13-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80
Building Drain - Sanitary	>	15

Type	Qualifier	Distance
Building Overhang		12
Sewer - Building Sanitary	>	30
Septic or Holding, or POWTS Tank		50

Comment:

Created On: 06-03-1992 Updated On: 06-03-1992 Review Status: