

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ES203		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner PETER MOTL						Phone # (715)726-2222		1. Well Location				Fire # (if avail.)							
Mailing Address 5300 MARS DR						Town of LAFAYETTE						Street Address or Road Name and Number STILLSON RD							
City CHIPPEWA FALLS				State WI		Zip Code 54729													
County Chippewa		Co. Permit # W06130		Notification #		Completed 04-09-1992		Subdivision Name			Lot #		Block #						
Well Constructor (Business Name) WETTSTEIN, MICHAEL J				Lic. # 206		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code							
Address RT 2 BOX 130C EAU CLAIRE WI 54703-9802				Well Plan Approval #		Approval Date (mm-dd-yyyy)		SE SW		Section 7		Township 28 N		Range 7 W					
								or Govt Lot #		Township 28 N		Range 7 W							
Hicap Permanent Well #				Common Well #		Specific Capacity		2. Well Type New Well											
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		of previous unique well # constructed in													
						Reason for replaced or reconstructed well ? NEW HOME													
4. Potential Contamination Sources - ON REVERSE SIDE						Construction Type Drilled													
						5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		42		Rotary - Mud Circulation Rotary - Air <u>Yes</u> Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 10in. dia <u>Yes</u> Removed? ___ depth ft. (If NO explain on back side)		T C T N		BROWN CLAY LIGHT BROWN SANDROCK		Surface 10		10 80					
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is									
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		50 ft. below ground surface				16 in. above grade					
6		NEW STEEL THREADED @ CUPPLED 20 LBS PER FT ASTMA53 B 1780 PSI VALLEY STEEL PIPE				Surface		42		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 50 ft. below surface Pumping at 18 GP for 3 Hrs. Pumping Method ?									
7. Grout or Other Sealing Material						12. Notified Owner of need to fill & seal ?													
Method PRESSURE TREMIE LINE						Filled & Sealed Well(s) as needed? Yes													
Kind of Sealing Material		From (ft.)		To (ft.)										# Sacks Cement					
CLEAR CEMENT @ WATER		Surface		42		12		13. Constructor / Supervisory Driller				Lic #		Date Signed					
MW						MW				05-13-1992		MW		05-13-1992					
										Drill Rig Operator						Lic or Reg #		Date Signed	
										MW						05-13-1992			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Building Overhang		12
Building Drain - Sanitary	>	15	Sewer - Building Sanitary	>	30
			Septic or Holding, or POWTS Tank		50

Comment:

Created On: 06-03-1992

Updated On: 06-03-1992

Review Status: