Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ES204

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: PETER LONIELLO	Phone #: (612)869-8962
Mailing Address: 1605 W 72 ST	
City: RICHFIELD	State: MN Zip Code: 55423
County: Dunn	Co. Permit #:	Notification #:	Completed: 04-08-1992
Well Constructor (Business Name): WETTSTEIN, MICHAEL J	Lic. #: 206
Address: RT 2 BOX 130C EAU CLAIRE WI 54703-9802	
Hicap Permanent Well #:	Common Well #:

Facility ID # (Public Wells):
Well Plan Approval #:
Approval Date (mm-dd-yyyy):
Specific Capacity: 9

1. Well Location
Town of TAINTER
Fire # (if avail.):
Street Address or Road Name and Number: TOWN ROAD
Subdivision Name: | Lot #: | Block #:
Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code:

NW	SW	Section	Township	Range
or Govt Lot #		29	29 N	12 W

2. Well Type New Well
of previous unique well #: constructed in
Reason for replaced or reconstructed well ?: NEED FOR WATER
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	33
6	33	100

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Yes Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes Temp. Outer Casing 10in. dia
- Yes Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		X		BROWN SAND @ CLAY	Surface	8
T		N		LIGHT BROWN SANDROCK	8	90
G		N		LIGHT GRAY SANDROCK	90	100

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STEEL THREADED @ CUPPLED 20 LBS PER FT ASMTA53B 1780 PSI VALLEY STEEL PIPE	Surface	33
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method PRESSURE TREMIE LINE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLEAR CEMENT @ WATER	Surface	33	10

9. Static Water Level
65 ft. below ground surface

10. Pump Test
Pumping level 67 ft. below surface
Pumping at 18 GP for 6 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
MW		05-13-1992
Drill Rig Operator	Lic or Reg #	Date Signed
MW		05-13-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70
Building Drain - Sanitary	>	15

Type	Qualifier	Distance
Building Overhang		15
Sewer - Building Sanitary	>	15
Septic or Holding, or POWTS Tank		37

Comment:

Created On: 06-03-1992 Updated On: 06-03-1992 Review Status: