

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				FI133		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner BAY LAKE BUILDERS						Phone # (414)437-7700		1. Well Location				Fire # (if avail.)									
Mailing Address 1411 S WEBSTER AVE						Town of SCOTT						Street Address or Road Name and Number PLACID WAY									
City GREEN BAY				State WI		Zip Code 54301															
County Brown		Co. Permit #		Notification #		Completed 05-27-1992		Subdivision Name ROYAL SCOT				Lot #		Block #							
Well Constructor (Business Name) VAN DE YACHT, LEO				Lic. # 31		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code							
Address 3383 OAK FOREST DR GREEN BAY WI 54313-7628				Well Plan Approval #		NE NE Section Township Range or Govt Lot # 16 24 N 22 E				2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? HOME											
						Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #		Common Well #		Specific Capacity 0.8		Construction Type Drilled															
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?																	
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method										8. Geology											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
9		Surface		62		Yes Rotary - Mud Circulation Yes Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				Z		CLAY @ GRAVEL		Surface		45					
6		62		142						P		HARDPAN		45		62					
										L		LIMESTONE		62		142					
6. Casing, Liner, Screen										9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		20 ft. below ground surface				12 in. above grade							
6		NEW BLACK STEEL PLAIN END WELDED ASTM-A-53B, 18.97# PER FT. SAWHILL PIPE				Surface		62		10. Pump Test Pumping level 60 ft. below surface Pumping at 30 GP for 2 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)													
7. Grout or Other Sealing Material										12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? No N/APP.											
Method																					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement													
DRILL SLURRY				Surface		62															
										13. Constructor / Supervisory Driller				Lic #		Date Signed					
										LV						05-27-1992					
										Drill Rig Operator				Lic or Reg #		Date Signed					
										TV						05-27-1992					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		15	Collector Sewer - San or Storm		100
Clearwater Sump		35	Foundation Drain to Clearwater		17
			Sewer - Building Sanitary		25

Comment:

Created On: 06-24-1992

Updated On: 06-24-1992

Review Status: