

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				FI136		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A																										
Property Owner ROBERT BOLSSSEN Phone # (414)434-0758						1. Well Location				Fire # (if avail.)																										
Mailing Address PO BOX 54307						Town of PITTSFIELD				Street Address or Road Name and Number COUNTY B																										
City GREEN BAY				State WI		Zip Code 54307																														
County Brown		Co. Permit #		Notification #		Completed 05-28-1992		Subdivision Name			Lot #		Block #																							
Well Constructor (Business Name) VAN DE YACHT, LEO				Lic. # 31		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code																								
Address 3383 OAK FOREST DR GREEN BAY WI 54313-7628				Well Plan Approval #		SW SW Section Township Range or Govt Lot # 12 25 N 19 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? HOME																												
Approval Date (mm-dd-yyyy)				Specific Capacity 0.8		Construction Type Drilled																														
Hicap Permanent Well #				Common Well #		Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled																												
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?																																
4. Potential Contamination Sources - ON REVERSE SIDE																																				
5. Drillhole Dimensions and Construction Method																																				
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="2" style="padding: 5px;">Geology Codes</th> <th style="padding: 5px;">Type, Caving/Noncaving, Color, Hardness, etc...</th> <th style="padding: 5px;">From (ft.)</th> <th style="padding: 5px;">To (ft.)</th> </tr> <tr> <td style="padding: 5px;"></td> <td style="padding: 5px;">S</td> <td style="padding: 5px;">SAND</td> <td style="padding: 5px;">Surface</td> <td style="padding: 5px;">20</td> </tr> <tr> <td style="padding: 5px;"></td> <td style="padding: 5px;">C</td> <td style="padding: 5px;">CLAY</td> <td style="padding: 5px;">20</td> <td style="padding: 5px;">95</td> </tr> <tr> <td style="padding: 5px;"></td> <td style="padding: 5px;">P</td> <td style="padding: 5px;">HARDPAN</td> <td style="padding: 5px;">95</td> <td style="padding: 5px;">104</td> </tr> <tr> <td style="padding: 5px;"></td> <td style="padding: 5px;">L</td> <td style="padding: 5px;">LIMESTONE</td> <td style="padding: 5px;">104</td> <td style="padding: 5px;">142</td> </tr> </table>		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)		S	SAND	Surface	20		C	CLAY	20	95		P	HARDPAN	95	104		L	LIMESTONE	104	142
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)																																
	S	SAND	Surface	20																																
	C	CLAY	20	95																																
	P	HARDPAN	95	104																																
	L	LIMESTONE	104	142																																
9		Surface		104		Yes Rotary - Mud Circulation Yes Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)																														
6		104		142																																
6. Casing, Liner, Screen																																				
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 60 ft. below ground surface		11. Well Is 12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes																								
6		NEW BLACK STEEL PLAIN END WELDED ASTM-A-53B, 18.97# PER FT. SAWHILL PIPE				Surface		104																												
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)																												
										10. Pump Test Pumping level 100 ft. below surface Pumping at 30 GP for 2 Hrs. Pumping Method ?		Filled & Sealed Well(s) as needed? No N/APP.																								
7. Grout or Other Sealing Material																																				
Method																																				
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement																												
DRILL SLURRY				Surface		104																														
12. Notified Owner of need to fill & seal ? No																																				
13. Constructor / Supervisory Driller								Lic #		Date Signed																										
LV										05-28-1992																										
Drill Rig Operator								Lic or Reg #		Date Signed																										
TV										05-28-1992																										

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Clearwater Sump		35
Building Overhang		14	Foundation Drain to Clearwater		16
			Septic or Holding, or POWTS Tank		55

Comment:

Created On: 06-24-1992

Updated On: 06-24-1992

Review Status: