Well Construction Report
WISCONSIN UNIQUE WELL NUMBER FI208

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: RAY BOWLING WELL	Phone #
Mailing Address: W164 BARTLAIN DR	
City: IXONIA	State: WI — Zip Code: 53036
County: Dodge	Co. Permit #	Notification #	Completed: 05-13-1992
Well Constructor (Business Name): HARTMAN, MICHAEL	Lic. #: 436 — Facility ID # (Public Wells)
Address: W82 N28280 MARSHALL HARTLAND WI 53029	Well Plan Approval # / Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #:	Specific Capacity: 0.8

1. Well Location

Town of LEBANON	Fire # (if avail.)
Street Address or Road Name and Number: RFD 1 654 CRAWFISH RD	
Subdivision Name	Lot #	Block #
Latitude / Longitude in Decimal Degree (DD): 43.21708 °N -88.56645 °W — Method Code: GPS008	
NE SW or Govt Lot #	Section: 26 — Township: 9 N — Range: 16 E

2. Well Type Replacement
of previous unique well # constructed in
Reason for replaced or reconstructed well ?: HOME-OLD WELL BAD
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	205

Upper Enlarged Drillhole / Lower Open Bedrock

Yes — Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	CLAY	Surface	18
P	HARDPAN	18	69
L	LIMESTONE	69	205

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	0.280 A-53 GR. B SAWHILL STEEL WELDED	Surface	69
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
90 ft. below ground surface

10. Pump Test
Pumping level 110 ft. below surface
Pumping at 15 GP for 4 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	20	

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? No
PUMP MAN TO DO

13. Constructor / Supervisory Driller	Lic #	Date Signed
MH		06-05-1992
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	<	100

Type	Qualifier	Distance
Building Overhang		11
Septic or Holding, or POWTS Tank	>	100

Comment:

Created On: 06-24-1992 Updated On: 08-19-2022 Review Status: