

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				FI239		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner MARTIN TUBBS						Phone # (414)965-3411		1. Well Location				Fire # (if avail.)	
Mailing Address W359 S1933 HWY 67						Town of OTTAWA							
City DOUSMAN						State WI		Zip Code 53118					
County Waukesha		Co. Permit #		Notification #		Completed 05-28-1992		Subdivision Name				Lot #	
												Block #	
Well Constructor (Business Name) HARTMAN, MICHAEL				Lic. # 436		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.0095 °N -88.4624 °W			
Address W82 N28280 MARSHALL HARTLAND WI 53029				Well Plan Approval #		Method Code GCD013							
						Approval Date (mm-dd-yyyy)							
Hicap Permanent Well #				Common Well #		Specific Capacity 0.4							
3. Well serves 1 # of						Hicap Well ? No		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? OLD POINT DRY Construction Type Drilled					
Private, potable						Hicap Property ? No							
Heat Exchange ___ # of drillholes						Hicap Potable ?							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock			
10		Surface		6									
6		6		265		Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
C		SURFACE CLAY				Surface		6					
G		GRAVEL				6		12					
S		SAND				12		85					
C S		SANDY CLAY				85		186					
P		HARDPAN				189		199					
L		LIMESTONE				199		265					
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		0.280 A-53 GR. B SAWHILL STEEL WELDED				Surface		199					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material													
Method													
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement							
DRILL CUTTINGS		Surface		6									
9. Static Water Level													
109 ft. below ground surface													
10. Pump Test													
Pumping level 140 ft. below surface													
Pumping at 13 GP for 4 Hrs.													
Pumping Method ?													
11. Well Is													
12 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed? No													
OWNER TO DO													
13. Constructor / Supervisory Driller													
Lic #		Date Signed											
MH		06-05-1992											
Drill Rig Operator		Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		120	Foundation Drain to Clearwater		10
Building Overhang		8	Sewer - Building Sanitary		50
Clearwater Sump		15	Septic or Holding, or POWTS Tank		60

Comment:

Created On: 06-24-1992

Updated On: 07-11-2019

Review Status: