Well Construction Report
WISCONSIN UNIQUE WELL NUMBER FI799

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: TOM HAYWARD			Phone #
Mailing Address: 6509 LEGEND LN			
City: WIND LAKE	State: WI	Zip Code: 53185	
County: Racine	Co. Permit #	Notification #	Completed: 06-03-1992

Well Constructor (Business Name): MORSE, RICHARD	Lic. #: 619	Facility ID # (Public Wells)	
Address: S78 W32552 SUGDEN RD MUKWONAGO WI 53149		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.7	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of NORWAY

Fire # (if avail.)

Street Address or Road Name and Number: 6509 LEGEND LN

Subdivision Name: WINDEMAR	Lot #: 00013	Block #

Latitude / Longitude in Decimal Degree (DD): 42.8085 °N -88.1467 °W
Method Code: GCD013

SW NW or Govt Lot #	Section: 16	Township: 4 N	Range: 20 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
WATER

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	112

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit 10in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	CLAY	Surface	72
S	SAND	72	75
C	CLAY	75	110
S	SAND	110	112

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 19 LBS ASTM-A53 SAWHILL WELDED	Surface	110
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	STAINLESS SLOT		

7. Grout or Other Sealing Material

Method BAILER

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	20	

9. Static Water Level
30 ft. below ground surface

10. Pump Test
Pumping level 45 ft. below surface
Pumping at 10 GP for 4 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
RM		06-03-1992
Drill Rig Operator	Lic or Reg #	Date Signed
RM		06-03-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		15	Downspout/Yard Hydrant		20
Collector Sewer - San or Storm		90	Sewer - Building Sanitary		55

Comment:

Created On: 06-19-1992 Updated On: 06-28-2019 Review Status: