

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				FI799		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner TOM HAYWARD						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 6509 LEGEND LN						Town of NORWAY							
City WIND LAKE						State WI		Zip Code 53185				Street Address or Road Name and Number 6509 LEGEND LN	
County Racine		Co. Permit #		Notification #		Completed 06-03-1992		Subdivision Name WINDEMAR				Lot # 00013	
Well Constructor (Business Name) MORSE, RICHARD				Lic. # 619		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.8085 °N -88.1467 °W			
Address S78 W32552 SUGDEN RD MUKWONAGO WI 53149				Well Plan Approval #		or Govt Lot # 16				Township 4 N		Method Code GCD013	
												Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #		Common Well #		Specific Capacity 0.7		Reason for replaced or reconstructed well ? WATER							
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No				Construction Type Drilled			
Heat Exchange ___ # of drillholes				Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock										
10 Surface 20			Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit 10in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)										
6 20 112													
8. Geology													
Dia. (in.) From (ft.) To (ft.)			Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.) To (ft.)				
10 Surface 20			C CLAY						Surface 72				
6 20 112			S SAND						72 75				
			C CLAY						75 110				
			S SAND						110 112				
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		STEEL 19 LBS ASTM-A53 SAWHILL WELDED				Surface		110					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
5		STAINLESS SLOT											
7. Grout or Other Sealing Material													
Method BAILER													
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement							
CLAY SLURRY		Surface		20									
9. Static Water Level													
30 ft. below ground surface													
10. Pump Test													
Pumping level 45 ft. below surface													
Pumping at 10 GP for 4 Hrs.													
Pumping Method ?													
11. Well Is													
14 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed?													
13. Constructor / Supervisory Driller													
Lic #		Date Signed											
RM		06-03-1992											
Drill Rig Operator													
Lic or Reg #		Date Signed											
RM		06-03-1992											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		15	Downspout/Yard Hydrant		20
Collector Sewer - San or Storm		90	Sewer - Building Sanitary		55

Comment:

Created On: 06-19-1992

Updated On: 06-28-2019

Review Status: