Well Construction Report
WISCONSIN UNIQUE WELL NUMBER FI802

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WILLIAM KOCH			Phone #: (708)428-7267
Mailing Address: 168 RED HAWK PATH			
City: GILBERTS	State: IL	Zip Code: 60136	
County: Adams	Co. Permit #: W05279	Notification #	Completed: 05-27-1992

Well Constructor (Business Name): MARSHALL, TERRY L	Lic. #: 216	Facility ID # (Public Wells)
Address: 1055 GILLETTE LN WISCONSIN DELLS WI 53965-8821		Well Plan Approval #
		Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #	Specific Capacity: 3.3

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of N.W. STRONGS PRAIRIE

Fire # (if avail.)

Street Address or Road Name and Number: 20TH AVE

Subdivision Name: TOMLINS PARK	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code

NE SE or Govt Lot #	Section: 36	Township: 18 N	Range: 4 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	40
6	40	62

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
S	SAND	Surface	12
N	SANDSTONE	12	62

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	P.E. STEEL PIPE ASTM-A-53 GR-B 18.97LBS/FT. LTVSTEEL USA	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
15 ft. below ground surface

10. Pump Test
Pumping level 21 ft. below surface
Pumping at 20 GP for 3 Hrs.
Pumping Method ?

11. Well Is
13 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method PRESSURE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PORTLAND CEMENT @ WATER	Surface	40	12

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
TLM		05-27-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
TLM		05-27-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Shoreline/Pool		45

Comment:

Created On: 06-19-1992 Updated On: 06-19-1992 Review Status: