

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				FI803		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner MICHAEL HORKAN						Phone # (608)847-7978		1. Well Location				Fire # (if avail.)											
Mailing Address BOX N 5815 HWY Q						Town of LISBON						Street Address or Road Name and Number											
City NEW LISBON				State WI		Zip Code 53950																	
County Juneau		Co. Permit #		Notification #		Completed 05-28-1992		Subdivision Name BEDROCK EST				Lot # 00012		Block #									
Well Constructor (Business Name) MARSHALL, TERRY L				Lic. # 216		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code									
Address 1055 GILLETTE LN WISCONSIN DELLS WI 53965-8821				Well Plan Approval #				°N		°W		NE SE Section Township Range or Govt Lot # 24 16 N 3 E											
				Approval Date (mm-dd-yyyy)																			
Hicap Permanent Well #		Common Well #		Specific Capacity 5				2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ?															
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?																			
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
8.75		Surface		42		Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 10in. dia <u>Yes</u> Removed? ___ depth ft. (If NO explain on back side)				S		SAND		Surface		6							
6		42		102						N		SANDSTONE		6		102							
6		42		102						S		SAND		Surface		6							
6		42		102						N		SANDSTONE		6		102							
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		54 ft. below ground surface				15 in. above grade									
6		P.E. STEEL PIPE ASTM-A-53 GR-B 18.97 LBS/FT.L.T.V. STEEL U.S.A.				Surface		42		10. Pump Test Pumping level 58 ft. below surface Pumping at 20 GP for 18 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)															
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?									
Method PRESSURE																							
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement																	
PORTLAND CEMENT @ WATER		Surface		42		11																	
														13. Constructor / Supervisory Driller				Lic #		Date Signed			
														TLM						05-28-1992			
														Drill Rig Operator				Lic or Reg #		Date Signed			
														TLM						05-28-1992			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		20	Foundation Drain to Clearwater		20

Comment:

Created On: 06-19-1992

Updated On: 06-19-1992

Review Status: