

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				FI951		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner JEROME GLUHEISEN						Phone # (715)866-7367		1. Well Location				Fire # (if avail.)			
Mailing Address 8176 CO RD D						Town of MEENON						8176			
City WEBSTER						State WI		Zip Code 54893				Street Address or Road Name and Number			
County Burnett		Co. Permit #		Notification #		Completed 04-28-1992		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) BEECROFT, GARY				Lic. # 137		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.8475 °N -92.4033 °W				Method Code GCD013	
Address 1318 350TH AVE SIREN WI 54872-9604				Well Plan Approval #		SW SW Section Township Range or Govt Lot # 19 39 N 16 W		2. Well Type Replacement				of previous unique well #		constructed in	
Hicap Permanent Well #		Common Well #		Specific Capacity 0.4		Reason for replaced or reconstructed well ? TO REPLACE SHALLOW POINT				Construction Type Drilled					
3. Well serves 1 # of				Hicap Well ? No		Private, potable				Hicap Property ? No		Heat Exchange ___ # of drillholes		Hicap Potable ?	
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
4		Surface		148.5		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
S M		SILTY SAND				Surface		6							
C		CLAY				6		13							
S M		SILTY SAND				13		41							
C S		SANDY CLAY				41		52							
C		CLAY				52		84							
P		HARD PAN				84		134							
S M		SILTY SAND				134		139							
S		SAND				139		148.5							
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
4		NEW BLACK STEEL ASTM A53 .237 WALL THICKNESS-10.79# PER FT. SAWHILL PIPE CO. WELDED JOINTS				Surface		144.5							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
4		STEEL SCREEN 10 SLOT STAINLESS				144		148.5							
7. Grout or Other Sealing Material															
Method BENTONITE GRANUELS															
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement									
WHILE DRIVING PIPE		Surface													
9. Static Water Level															
25 ft. below ground surface															
10. Pump Test															
Pumping level 70 ft. below surface															
Pumping at 20 GP for 2 Hrs.															
Pumping Method ?															
11. Well Is															
12 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? No															
OWNER WILL SEAL															
13. Constructor / Supervisory Driller				Lic #		Date Signed									
GB						05-31-1992									
Drill Rig Operator				Lic or Reg #		Date Signed									
TB						05-31-1992									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		112	Building Overhang		33
			Septic or Holding, or POWTS Tank		87

Comment:

Created On: 06-19-1992

Updated On: 06-30-2020

Review Status: