Well Construction Report
WISCONSIN UNIQUE WELL NUMBER FI951

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JEROME GLUHEISEN	Phone #: (715)866-7367
Mailing Address: 8176 CO RD D	
City: WEBSTER	State: WI — Zip Code: 54893
County: Burnett	Co. Permit #: — Notification #: — Completed: 04-28-1992
Well Constructor (Business Name): BEECROFT, GARY	Lic. #: 137 — Facility ID # (Public Wells):
Address: 1318 350TH AVE, SIREN WI 54872-9604	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.4

1. Well Location

Town of MEENON	Fire # (if avail.): 8176
Street Address or Road Name and Number:	
Subdivision Name: — Lot #: — Block #:	
Latitude / Longitude in Decimal Degree (DD): 45.8475 °N -92.4033 °W	Method Code: GCD013
SW SW or Govt Lot #	Section: 19 — Township: 39 N — Range: 16 W

2. Well Type Replacement

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

TO REPLACE SHALLOW POINT

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	148.5

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S	M	SILTY SAND	Surface	6
		C		CLAY	6	13
		S	M	SILTY SAND	13	41
		C	S	SANDY CLAY	41	52
		C		CLAY	52	84
		P		HARD PAN	84	134
		S	M	SILTY SAND	134	139
		S		SAND	139	148.5

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW BLACK STEEL ASTM A53 .237 WALL THICKNESS-10.79# PER FT. SAWHILL PIPE CO. WELDED JOINTS	Surface	144.5
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	STEEL SCREEN 10 SLOT STAINLESS	144	148.5

7. Grout or Other Sealing Material

Method BENTONITE GRANUELS

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
WHILE DRIVING PIPE	Surface		

9. Static Water Level

25 ft. below ground surface

10. Pump Test

Pumping level 70 ft. below surface

Pumping at 20 GP for 2 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

OWNER WILL SEAL

13. Constructor / Supervisory Driller	Lic #	Date Signed
GB		05-31-1992
Drill Rig Operator	Lic or Reg #	Date Signed
TB		05-31-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		112	Building Overhang		33
			Septic or Holding, or POWTS Tank		87

Comment:

Created On: 06-19-1992 Updated On: 06-30-2020 Review Status: