

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				FJ106		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner PAT GAMSKY						Phone #		1. Well Location				Fire # (if avail.)		
Mailing Address 2110 PALISADES DR						Town of GREENVILLE						Street Address or Road Name and Number		
City APPLETON				State WI		Zip Code 54915								
County Outagamie		Co. Permit #		Notification #		Completed 06-05-1992		Subdivision Name HARVEST MEADOWS			Lot # 00020		Block #	
Well Constructor (Business Name) VAN DE YACHT, BILL WTR WELL @ SP				Lic. # 4462		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code			
Address A4151 LEDGECREST RD DE PERE WI 54115-9711				Well Plan Approval #		NE SW		Section 34		Township 21 N		Range 16 E		
				Approval Date (mm-dd-yyyy)		or Govt Lot #		Township 21 N		Range 16 E				
Hicap Permanent Well #		Common Well #		Specific Capacity 0.7		2. Well Type New Well of previous unique well # constructed in								
3. Well serves 1 # of Private, potable Heat Exchange ____ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Reason for replaced or reconstructed well ? Construction Type Drilled								
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				
9		Surface		83		Yes Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)								
6		83		181										
8. Geology														
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)						
S		SAND				Surface		10						
C		CLAY				10		75						
G		GRAVEL				75		83						
L		LIME				83		175						
N		SANDSTONE				175		180						
L		LIMESTONE				180		181						
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
6		NEW BL. STL. PL. END WELDED 18.97 280 A53 SAWHILL				Surface		84						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
7. Grout or Other Sealing Material		Method												
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement								
DRILL SLURRY		Surface		83										
9. Static Water Level 60 ft. below ground surface														
10. Pump Test Pumping level 120 ft. below surface Pumping at 40 GP for 1 Hrs. Pumping Method ?														
11. Well Is 12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes														
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?														
13. Constructor / Supervisory Driller						Lic #		Date Signed						
BV								06-05-1992						
Drill Rig Operator						Lic or Reg #		Date Signed						
BV								06-05-1992						

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Septic or Holding, or POWTS Tank		80

Comment:

Created On: 06-24-1992

Updated On: 06-24-1992

Review Status: