

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				FJ107		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner HOFFMAN @ STROEBEL						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address 3409 MARIAH LN						Town of ELLINGTON						Street Address or Road Name and Number			
City APPLETON				State WI		Zip Code 54911									
County Outagamie		Co. Permit #		Notification #		Completed 06-02-1992		Subdivision Name			Lot #		Block #		
Well Constructor (Business Name) VAN DE YACHT, BILL WTR WELL @ SP				Lic. # 4462		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code			
Address A4151 LEDGECREST RD DE PERE WI 54115-9711				Well Plan Approval #		Approval Date (mm-dd-yyyy)		°N		°W		Range			
								NE		SE				Section 3	
Hicap Permanent Well #				Common Well #		Specific Capacity 1		2. Well Type New Well							
3. Well serves 1 # of						Hicap Well ? No		Reason for replaced or reconstructed well ?							
Private, potable						Hicap Property ? No									
Heat Exchange ___ # of drillholes						Hicap Potable ?									
Construction Type Drilled															
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)			From (ft.)			To (ft.)			Upper Enlarged Drillhole					Lower Open Bedrock	
9			Surface			104			Yes Rotary - Mud Circulation					Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)	
6			104			181			Rotary - Air						
Rotary - Air & Foam															
Drill-Through Casing Hammer															
Reverse Rotary															
Cable-tool Bit ___ in. dia...															
Dual Rotary															
Temp. Outer Casing ___ in. dia									Removed? ___ depth ft. (If NO explain on back side)						
Removed? ___ depth ft. (If NO explain on back side)															
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
Y				SAND @ GRAVEL				Surface		80					
P				HARDPAN				80		104					
X L N				LIME SANDSTONE MIXED				104		181					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		NEW BL. STL. PL. END WELDED 18.97 280 A53 SAWHILL				Surface		105							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material		Method				From (ft.)		To (ft.)		# Sacks Cement					
Kind of Sealing Material		DRILL SLURRY				Surface		104							
9. Static Water Level															
60 ft. below ground surface															
10. Pump Test															
Pumping level 100 ft. below surface															
Pumping at 40 GP for 1 Hrs.															
Pumping Method ?															
11. Well Is															
12 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed?															
13. Constructor / Supervisory Driller								Lic #		Date Signed					
BV										06-05-1992					
Drill Rig Operator								Lic or Reg #		Date Signed					
BV										06-05-1992					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Septic or Holding, or POWTS Tank		80

Comment:

Created On: 06-24-1992

Updated On: 06-24-1992

Review Status: