Well Construction Report
WISCONSIN UNIQUE WELL NUMBER FJ597

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GERALD ENDRIES			Phone #: (715)669-3989
Mailing Address: 53338 HWY 13			
City: SPENCER	State: WI	Zip Code: 54479	
County: Marathon	Co. Permit #:	Notification #:	Completed: 05-20-1992

Well Constructor (Business Name): BRUNNER, WILLIAM D	Lic. #: 515	Facility ID # (Public Wells):	
Address: 303 S 8TH MEDFORD WI 54451-1904		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.1	

1. Well Location

Town of SPENCER

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code:
SW SW or Govt Lot #:	Section: 9	Township: 26 N	Range: 2 E

2. Well Type New Well

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: NEW CONST.

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	46

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
- Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C		CLAY	Surface	18
U		C		BLUE CLAY	18	40
		S		SAND	40	46

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLK STL T@C A53B 19.45# VSP 1780 PSI	Surface	43
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	STAINLESS STEEL #12	43	46

9. Static Water Level

1 ft. below ground surface

10. Pump Test

Pumping level 8 ft. below surface

Pumping at 8 GP for 2 Hrs.

Pumping Method ?

11. Well Is

26 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILL CUTTINGS	Surface	20	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
WDB		06-03-1992
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		15	Sewer - Building Sanitary		40
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 06-19-1992 Updated On: 06-19-1992 Review Status: