

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				FJ598		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner RUSS ALGER						Phone # (715)669-3583		1. Well Location				Fire # (if avail.)					
Mailing Address N14669 DICKERSON AVE						Town of THORP						Street Address or Road Name and Number					
City THORP				State WI		Zip Code 54771											
County Clark		Co. Permit #		Notification #		Completed 05-19-1992		Subdivision Name				Lot #		Block #			
Well Constructor (Business Name) BRUNNER, WILLIAM D				Lic. # 515		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code					
Address 303 S 8TH MEDFORD WI 54451-1904				Well Plan Approval #		NE SE		Section 34		Township 29 N		Range 4 W					
				Approval Date (mm-dd-yyyy)		or Govt Lot #		Range		W							
Hicap Permanent Well #		Common Well #		Specific Capacity 0.1		2. Well Type New Well											
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		of previous unique well # _____ constructed in _____									
						Hicap Property ? No											
Heat Exchange ___ # of drillholes						Hicap Potable ?		Reason for replaced or reconstructed well ?									
						Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
8		Surface		40		Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 8in. dia <u>Yes</u> Removed? ___ depth ft. (If NO explain on back side)		C CLAY Q GRANITE		Surface 8 200		8 200					
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		16 ft. below ground surface				24 in. above grade			
6		NEW BLK. STL. P.E. 18.97# A53B SAWHILL				Surface		40		10. Pump Test Pumping level 160 ft. below surface Pumping at 8 GP for 2 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
7. Grout or Other Sealing Material Method INSIDE TREMIE						12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?											
Kind of Sealing Material		From (ft.)		To (ft.)								# Sacks Cement					
NEAT CEMENT		Surface		40		8		13. Constructor / Supervisory Driller				Lic #		Date Signed			
												06-03-1992					
Drill Rig Operator						Lic or Reg #				Date Signed							

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 06-24-1992

Updated On: 06-24-1992

Review Status: