Well Construction Report
WISCONSIN UNIQUE WELL NUMBER FJ867

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DAN WILLIAMS	Phone #: (715)824-2366
Mailing Address: PO BOX 353	
City: AMHERST	State: WI — Zip Code: 54406
County: Portage	Co. Permit #: — Notification #: — Completed: 10-20-1992
Well Constructor (Business Name): FARAGO PLUMBING @ TRENCHING INC	Lic. #: 126 — Facility ID # (Public Wells):
Address: 606 W POPLAR ST, PLAINFIELD WI 54966-9620	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 6

1. Well Location
Town of AMHERST
Fire # (if avail.):
Street Address or Road Name and Number: 3948 HWY T
Subdivision Name: — Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:
SW NE or Govt Lot #: — Section: 15 — Township: 23 N — Range: 10 E

2. Well Type New Well
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?:
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	118

Upper Enlarged Drillhole — Lower Open Bedrock
Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	M	CLAY LOAM	Surface	10
	N	Y		FINE SAND @ GRAVEL	10	63
		C		CLAY @	63	83
	N	S		FINE SAND	83	108
	M	S		MED SAND	108	118

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A1 USS STEEL A53 19.97#PER FT.-WELDEDTOGETHER, 6.625"ODX2.80 WALL-TESTED 2800 PSITOTAL WT. 2276.58	Surface	114
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	#12 COOK WITH KPACKER	114	118

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
POWDER BENTONITE ALONG CASING	Surface	0	

9. Static Water Level
54 ft. below ground surface

10. Pump Test
Pumping level 56 ft. below surface
Pumping at 12 GP M for 1.05 Hrs.
Pumping Method ?

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
JF		10-21-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
TF		10-20-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		13

Comment:

Created On: 12-07-1992 Updated On: 12-07-1992 Review Status: