Well Construction Report
WISCONSIN UNIQUE WELL NUMBER FK399

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RUX, RODNEY			Phone #
Mailing Address			
City: MUSCODA	State: WI	Zip Code: 53573	
County: Sauk	Co. Permit #	Notification #	Completed: 01-18-1993

1. Well Location

Town of LAVALLE

Fire # (if avail.)

Street Address or Road Name and Number: W REDSTONE DR

Subdivision Name	Lot #	Block #
WOODPECKER		

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
MCAFEE WELL DRILLING	5893	

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

Well Plan Approval #

NE	NE	Section	Township	Range
or Govt Lot #		12	13 N	3 E

Address: PO BOX 106
LA VALLE WI 53941-0106

Approval Date (mm-dd-yyyy)

2. Well Type New Well

of previous unique well # constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity

Reason for replaced or reconstructed well ?

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	30
8	30	45
6	45	75

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Yes Cable-tool Bit 8in. dia...

Dual Rotary .....

Yes Temp. Outer Casing 8in. dia

No Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C		CLAY	Surface	7
		N		SANDSTONE	7	21
	W	B	U	SAND @ WATER MUCK	21	30
T		N		BROWN SANDSTONE	30	75

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
8	WELDED JOINT SAWHILL	Surface	30
6	280 WALL ASTME A53 6.625 X 280 BEL 21 HEAT 72 81	30	45
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

22 ft. above ground surface

10. Pump Test

Pumping level 22 ft. below surface

Pumping at 12 GP M for 24 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method GROUT PUMP TREMIE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PORTLAND	Surface	45	21 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

WASN'T ANY

13. Constructor / Supervisory Driller	Lic #	Date Signed
TM		12-20-1993
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		12	Foundation Drain to Clearwater		12
			Septic or Holding, or POWTS Tank		28

Comment: DNR APPROV TO LEAVE 8" CASING W/DRIVE SHOE TO CASETHRU VOID 21-30' CASING PRESSURE CMT W/TREMIE 45 TO SURFACE. PRESSURE CMT 21' TO SURFACE

Created On: 01-26-1994 Updated On: 10-15-2026 Review Status: