

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				FL441		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner KEN DULL						Phone # (715)246-5478		1. Well Location				Fire # (if avail.)			
Mailing Address 1034 CTY E						Town of RICHMOND						1034			
City NEW RICHMOND						State WI		Zip Code 54017				Street Address or Road Name and Number			
County St. Croix		Co. Permit #		Notification #		Completed 04-28-1993		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) MICHAEL D BEINBORN				Lic. # 75		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code			
Address 501 E OAK ST BOSCOBEL WI 53805-1434				Well Plan Approval #		SE SW		Section 32		Township 30 N		Range 18 W			
Hicap Permanent Well #				Common Well #		Specific Capacity 1		2. Well Type Replacement of previous unique well # constructed in							
Heat Exchange ____ # of drillholes				Hicap Well ? No		Hicap Property ? No		Reason for replaced or reconstructed well ? 4 X 35 WELL PUMPING SHORT							
3. Well serves 1 # of Private, potable				Hicap Potable ?		Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock									
10		Surface		42		Rotary - Mud Circulation									
6		42		65		<u>Yes</u> Rotary - Air									
						Rotary - Air & Foam									
						Drill-Through Casing Hammer									
						Reverse Rotary									
						Cable-tool Bit ____ in. dia...									
						Dual Rotary									
						Temp. Outer Casing ____ in. dia									
						Removed? ____ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
T		Y		SAND @ GRAVEL BRN SFT				Surface		22					
Y		L		LIMESTONE YEL HD				22		65					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		STL, HKK, 18.97# P.E. WELDED				Surface		42							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method PRESSURE TRIMME															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
NEAT CEMENT				Surface		0									
9. Static Water Level															
35 ft. below ground surface															
10. Pump Test															
Pumping level 50 ft. below surface															
Pumping at 15 GP M for 1 Hrs.															
Pumping Method ?															
11. Well Is															
12 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? Yes															
13. Constructor / Supervisory Driller															
Lic #								Date Signed							
TA								06-18-1993							
Drill Rig Operator								Lic or Reg #							
GS								Date Signed							
								04-29-1993							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70	Building Overhang		12
			Septic or Holding, or POWTS Tank		45

Comment:

Created On: 08-24-1993

Updated On: 08-24-1993

Review Status: