

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				FM578		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A																																						
Property Owner HATKOWSKI, LEROY						Phone # (715)824-2859		1. Well Location				Fire # (if avail.)																																				
Mailing Address HWY T 4269						Town of AMHERST						Street Address or Road Name and Number CTY T 4269																																				
City AMHERST				State WI		Zip Code 54406																																										
County		Co. Permit #		Notification #		Completed 10-14-1993		Subdivision Name				Lot #		Block #																																		
Portage				Well Constructor (Business Name) LEONARD K MAVES				Lic. # 190		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code																														
Address 5762 MJELDE RD AMHERST WI 54406-9023								Well Plan Approval #				°N °W		NW NW Section Township Range or Govt Lot # 23 23 N 10 E																																		
				Approval Date (mm-dd-yyyy)																																												
Hicap Permanent Well #				Common Well #		Specific Capacity 2.1				2. Well Type New Well																																						
Reason for replaced or reconstructed well ?						NEW HOME																																										
Heat Exchange ___ # of drillholes																																																
3. Well serves 1 # of						Hicap Well ? No						Construction Type Drilled																																				
Private, potable						Hicap Property ? No																																										
Hicap Potable ?																																																
4. Potential Contamination Sources - ON REVERSE SIDE																																																
5. Drillhole Dimensions and Construction Method														8. Geology																																		
Dia. (in.)			From (ft.)			To (ft.)			Upper Enlarged Drillhole						Lower Open Bedrock						Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)																
4			Surface			128			Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						Q Y SAND @ GRAVEL C CT BR SOFT						Surface		21																									
4			Surface			128															Q X FINE SAND @ CLAY GRAY SOFT						21		42																			
																											V X FIND SAND @ CLAY - NC GRAY HARD						42		63													
																																	V Y C COURSE SAND NC @ SMALL GRAVEL CLAY HARD						63		84							
																																							Q Y C COUSE SAND @ GRAVEL CLAY C LT BROWN						84		105	
																																													Q Y COURSE SAND @ GRAVEL BROWN SOFT C			
6. Casing, Liner, Screen														Method																																		
Dia. (in.)			Material, Weight, Specification Manufacturer & Method of Assembly						From (ft.)			To (ft.)																																				
4			MAVERICK ASTM A53GR8 BE 4.5 10.79 VICTOR TESTED 2210 TREADED @ COUPLED						Surface			125																																				
Dia. (in.)			Screen type, material & slot size						From (ft.)			To (ft.)																																				
4			STAINLESS STEEL 15 SLOT						124			128																																				
7. Grout or Other Sealing Material														Method																																		
Method																																																

9. Static Water Level

73 ft. below ground surface

10. Pump Test

Pumping level 80 ft. below surface

Pumping at 15 GP M for 12 Hrs.

Pumping Method ?

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

No

NONE

13. Constructor / Supervisory Driller

Lic #

Date Signed

LM

12-15-1993

Drill Rig Operator

Lic or Reg #

Date Signed

CA

10-27-1993

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		77	Landfill		1300
Building Overhang		9	Sewer - Building Sanitary		55
			Septic or Holding, or POWTS Tank		75

Comment:

Created On: 06-16-1994

Updated On: 06-16-1994

Review Status: