Well Construction Report
WISCONSIN UNIQUE WELL NUMBER FM578

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HATKOWSKI, LEROY	Phone #: (715)824-2859
Mailing Address: HWY T 4269	
City: AMHERST	State: WI — Zip Code: 54406
County: Portage	Co. Permit #: — Notification #: — Completed: 10-14-1993
Well Constructor (Business Name): LEONARD K MAVES	Lic. #: 190 — Facility ID # (Public Wells):
Address: 5762 MJELDE RD AMHERST WI 54406-9023	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 2.1

1. Well Location

Fire # (if avail.):

Town of AMHERST

Street Address or Road Name and Number: CTY T 4269

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

NW or Govt Lot #	NW	Section	Township	Range
		23	23 N	10 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?

NEW HOME

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	128

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	MAVERICK ASTM A53GR8 BE 4.5 10.79 VICTOR TESTED2210 TREADED @ COUPLED	Surface	125
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	STAINLESS STEEL 15 SLOT	124	128

7. Grout or Other Sealing Material

Method

8. Geology

Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Q	Y		SAND @ GRAVEL C CT BR SOFT	Surface	21
Q	X		FINE SAND @ CLAY GRAY SOFT	21	42
V	X		FIND SAND @ CLAY - NC GRAY HARD	42	63
V	Y	C	COURSE SAND NC @ SMALL GRAVEL CLAY HARD	63	84
Q	Y	C	COUSE SAND @ GRAVEL CLAY C LT BROWN	84	105
Q	Y		COURSE SAND @ GRAVEL BROWN SOFT C	105	128

9. Static Water Level

73 ft. below ground surface

10. Pump Test

Pumping level 80 ft. below surface

Pumping at 15 GP M for 12 Hrs.

Pumping Method ?

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
LM		12-15-1993
Drill Rig Operator	Lic or Reg #	Date Signed
CA		10-27-1993

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		77
Building Overhang		9
Landfill		1300
Sewer - Building Sanitary		55
Septic or Holding, or POWTS Tank		75

Comment:

Created On: 06-16-1994 Updated On: 06-16-1994 Review Status: