Well Construction Report
WISCONSIN UNIQUE WELL NUMBER FM579

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SEVICK, RICK			Phone #
Mailing Address: 3080 CUSTER RD			
City: CUSTER	State: WI	Zip Code: 54423	
County: Portage	Co. Permit #	Notification #	Completed: 10-09-1993

Well Constructor (Business Name): LEONARD K MAVES	Lic #: 190	Facility ID # (Public Wells)	
Address: 5762 MJELDE RD AMHERST WI 54406-9023		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 3.8	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of STOCKTON

Fire # (if avail.)

Street Address or Road Name and Number: 3080 CUSTER RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
44.5029 °N	-89.4277 °W			GCD013
SE NE or Govt Lot #		Section: 5	Township: 23 N	Range: 9 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	84

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	Q	Y		SAND @ GRAVEL BR. SOFT C	Surface	21
	Q	Y		SAND @ GRAVE BR. SOFT C	21	42
	Q	Y		SAND @ GRAVEL BR. SOFT C	42	63
	Q	Y		SAND @ GRAVEL BR. SOFT C	63	84

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW BLACK STEEL MAVERICK ASTM TREADED COUPLEDA53GR8 4.5 10.79 VICTOR TESTED 2210	Surface	81
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
	4IN X 4 15 SLOT STAINLESS STEEL	80	84

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NONE	Surface	0	

9. Static Water Level
26 ft. below ground surface

10. Pump Test
Pumping level 30 ft. below surface
Pumping at 15 GP M for 12 Hrs.
Pumping Method ?

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
LM		12-15-1993
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
CAA		10-11-1993

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60
Building Overhang		6

Type	Qualifier	Distance
Sewer - Building Sanitary		25
Septic or Holding, or POWTS Tank		48

Comment:

Created On: 06-16-1994 Updated On: 05-07-2020 Review Status: