

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				FM652		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner MARGARET SMITH						Phone # (715)382-4344		1. Well Location				Fire # (if avail.)		
Mailing Address RT 8 BOX 364						Town of LAFAYETTE						Street Address or Road Name and Number		
City CHIPPEWA FALLS				State WI		Zip Code 54729								
County Chippewa		Co. Permit # W06241		Notification #		Completed 12-21-1992		Subdivision Name CSM 776			Lot # 3		Block #	
Well Constructor (Business Name) DANIEL B OLSON				Lic. # 352		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)			Method Code			
Address 3188 SUNDET RD EAU CLAIRE WI 54703-0346				Well Plan Approval #		Approval Date (mm-dd-yyyy)		°N °W		SW SW Section Township Range or Govt Lot # 32 29 N 7 W		2. Well Type New Well		
								of previous unique well # constructed in						
Hicap Permanent Well #		Common Well #		Specific Capacity 3		Reason for replaced or reconstructed well ? NEW HOME								
3. Well serves 1 # of Private, potable				Hicap Well ? No		Construction Type Drilled								
Heat Exchange ___ # of drillholes				Hicap Property ? No										
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.) 6		From (ft.) Surface		To (ft.) 56		Upper Enlarged Drillhole Lower Open Bedrock								
Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		8. Geology												
		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
		I		TOPSOIL				Surface		1				
		S		SAND				1		6				
		Y		SAND @ GRAVEL				6		56				
		6. Casing, Liner, Screen												
		Dia. (in.) 6		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) Surface		To (ft.) 53				
6 STEEL T@C NEW BLACK 19.45# PER FT .280 WALL ASTMA53 SAWHILL STEEL		9. Static Water Level												
Dia. (in.) 6		Screen type, material & slot size				From (ft.) 53		To (ft.) 56		43 ft. below ground surface				
6 3' STAINLESS		10. Pump Test												
7. Grout or Other Sealing Material Method		Pumping level 48 ft. below surface				Pumping at 15 GP M for 2 Hrs. Pumping Method ?				11. Well Is				
		Pumping Method ?								14 in. above grade				
12. Notified Owner of need to fill & seal ?														
Filled & Sealed Well(s) as needed?														
13. Constructor / Supervisory Driller						Lic #		Date Signed						
DBO						Lic or Reg #		Date Signed						
Drill Rig Operator						Date Signed		12-28-1992						
DBO						Date Signed		12-28-1992						

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Type	Qualifier	Distance
Shoreline/Pool		50

Comment:

Created On: 01-20-1993

Updated On: 01-20-1993

Review Status: