Well Construction Report
WISCONSIN UNIQUE WELL NUMBER FM703

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BJORNSTAD, DARYL	Phone #: (415)366-8929
Mailing Address: 613 7TH ST N	
City: HUDSON	State: WI — Zip Code: 54016
County: St. Croix	Co. Permit #: — Notification #: — Completed: 01-06-1995
Well Constructor (Business Name): DAVID L MCCULLOUGH	Lic. #: 72 — Facility ID # (Public Wells):
Address: 20335 FOREST BLVD N, FOREST LAKE MN 55025-9764	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.2

1. Well Location

Town of ST JOSEPH

Fire # (if avail.):

Street Address or Road Name and Number: 292 ARBER HILL DR

Subdivision Name	Lot #	Block #
ARBER HILLS	5	

Latitude / Longitude in Decimal Degree (DD): 45.0693 °N -92.7413 °W — Method Code: GCD013

SE or Govt Lot #	SE	Section	Township	Range
		24	30 N	20 W

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	262

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
I	TOP SOIL	Surface	2
Y	SAND GRAVEL	2	140
Z	CLAY GRAVEL	140	220
G	GRAVEL	220	266

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	ASTMA53 IPSCO CAMANCHE 11 LB 237 TC	Surface	262
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
2	STAINLESS STEEL SCREEN	260	266

7. Grout or Other Sealing Material

Method TREMIE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTNITE GROUT	Surface	20	2 S
DRILL MUD	20	262	

9. Static Water Level

180 ft. below ground surface

10. Pump Test

Pumping level 235 ft. below surface

Pumping at 10 GP M for 0.5 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DM		01-09-1995
Drill Rig Operator	Lic or Reg #	Date Signed
DB		01-09-1995

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Building Overhang		26
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 06-26-1995 Updated On: 07-18-2019 Review Status: